

WATER TREATMENT DIVISION

READING & MEASUREMENT

SENSORI, SONDE E CELLE SENSORS, PROBE AND CELLS



CARATTERISTICHE GENERALI GENERAL FEATURES



D.CL.P CLORO CHLORINE

- **SENSORE POTENZIOSTATICO** per la misura del **CLORO LIBERO O TOTALE**
- **POTENTIOSTATIC SENSOR** for the measure of **FREE OR TOTAL CHLORINE**

CARATTERISTICHE TECNICHE TECHNICAL FEATURES

MODELLI MODELS	D.CL.P 01 I cloro libero inorganico free inorganic chlorine	D.CL.P 02 O cloro libero organico free organic chlorine	D.CL.P 03 I cloro libero inorganico free inorganic chlorine	D.CL.P 04 I cloro libero inorganico free inorganic chlorine	D.CL.P 05 I cloro libero inorganico free inorganic chlorine	D.CL.P 06 I cloro libero inorganico free inorganic chlorine	D.CL.P 07 I cloro libero inorganico free inorganic chlorine	D.CL.P 08 I cloro libero inorganico free inorganic chlorine	D.CL.P 09 I cloro libero inorganico free inorganic chlorine	D.C.T.O I cloro totale total chlorine	D.B.C 01 biossido di cloro chlorine dioxide
RANGE (ppm)	0÷10	0÷10	0÷10	0÷200	0÷2	0÷1	0÷5	0÷1	0÷5	0÷10	0÷10
RANGE pH	4÷8	4÷12	4÷11	4÷8	4÷8	5÷9	5÷9	5÷9	5÷9	0÷14	0÷14
RISOLUZIONE RESOLUTION (ppm)	±0,01	±0,01	±0,01	±0,01	±0,01	±0,01	±0,01	±0,01	±0,01	±0,01	±0,01
TEMPERATURA TEMPERATURE	45°C	45°C	45°C	45°C	45°C	50°C	50°C	70°C	70°C	70°C	45°C
PRESSIONE PRESSURE	1 bar	0,5 bar	0,5 bar	0,5 bar	0,5 bar	5 bar	5 bar	8 bar	8 bar	0,5 bar	0,5 bar
MEMBRANE DIAPHRAGMS	M.01	M.02	M.03	M.03	M.03	M.03	M.03	M.03	M.03	M.C.T.O	M.B.C
ELETTROLITI ELECTROLYTES	E.CLI 01	E.CLI 02	E.CLI 03	E.CLI 03	E.CLI 03	E.CLI 03	E.CLI 03	E.CLI 03	E.CLI 03	E.C.T.O	E.B.C
TENSIONE VOLTAGE	12÷30 VAC										
PORTATA FLOW RATE	≥30 lt/h (tempo stabilizzazione in media 15 min, massimo 1 ora stabilization time average 15 min, max 1 hour)										
USCITA SEGNALE SIGNAL OUTPUTS	4÷20 mA (uscita segnale corrente proporzionale alla misura output of current signal proportional to the measurement)										
CAVO CABLE	max 15 m										
MATERIALE MATERIAL	PVC										
DIMENSIONI DIMENSIONS	225 x 25 mm (HxD)										